

तार, "विस्फोटक" - नागपुर
Telegram - "EXPLOSIVES", Nagpur
वेबसाइट - <http://peso.gov.in>
ईमेल - explosives@explosives.gov.in
टेलीफोन - 0712 - 2510248
फैक्स - 0712 - 2510577
कार्यालयीन उद्देश्य के सभी पत्रादि मुख्य " के पदना "विस्फोटक नियंत्रक से भेजे जाए, उनके व्यक्तिगत नाम से नहीं
All communications intended for this office should be addressed to the "Chief Controller of Explosives" and not to him by name.



भारत सरकार
GOVERNMENT OF INDIA
पेट्रोलियम तथा विस्फोटक सुरक्षा संगठन
Petroleum and Explosives Safety Organisation

- पूर्ववर्ती विस्फोटक विभाग (Formerly - Department of Explosives)
ए, केन्द्रीय कार्यालय परिसर, पाँचवा तल, ब्लॉक-
A-Block, 5th Floor, C.G.O. Complex,
सेमिनरी हिल्स नागपुर, (महाराष्ट्र) - (440 006
Seminary Hills, Nagpur (Maharashtra) - 440 006

पत्रांक / No. No. G(40)/Misc/Petroleum/2024

दिनांक / Dated : 30.04.2026

To

M/s. Rahul Arts India Pvt. Ltd.,
8/33, First Floor, Tilak Nagar,
Above Nainital Bank,
New Delhi - 110018

Sub: Approval for manufacture and Use of "RAIPL" make HDPE (Non-Metallic Piping) underground flexible piping confirming to EN14125:2025 for MS & HSD from UG storage tank to dispensing unit at retail outlet - Reg.

Sir,

Reference inspection report of Jt. Chief Controller of Explosives, Faridabad vide his memo no. G(40)Misc/Petroleum/HDPE/2024 dated 22/04/2026 on the subject cited above,

Considering clarification and details furnished by you, there would be no objection to manufacture and usage of your subject flexible HDPE piping system being manufactured at admeasuring 9 Kanal 13 Marlas (1.20625 acres) vide out of Khewat no. 347/316, Khatoni no. 364, Rectangle no. 76 Kila no. 11 (4-8), 20/1 (0-14), Rectangle no. 77 Kila no. 15/2 (3-8), 16/1 (1-3) total admeasuring - 9 Kanal 13 Marlas in the revenue estate of village Rohad, Tehsil Bahadurgarh, District Jhajjar, Haryana for underground application in retail outlets.

1. All metallic parts in the piping system shall be grounded as per the requirements of EN14125-2025 ensure that the resistance to the earth and the metallic parts is maintained less than 100Ω during the entire service life of the pipeline.
2. An undertaking shall be given to the licensing authority at the time of obtaining a licence for the retail outlet where the pipeline is being installed to the effect that the same has been installed as per the manufacturer's specifications.
3. The pipelines in the retail outlets shall be installed by technical personnel specifically for the purpose.
4. Record of periodical earth resistance reading to be maintained by the user.
5. Approval granted will be valid for **Three Yeas upto 30/05/2029** and further extension will be considered only on submission of performance report from installer/user.

The approval is liable to be withdrawn at any time if found that the pipes do not conform to the requirements of manufacturing standards/specifications or are not installed properly or otherwise if found unsafe.

Yours faithfully

(H.P. Sangole)

Controller of Explosives
for Chief Controller of Explosives

Copy to All Circle & Sub-Circle.

for Chief Controller of Explosives